#### FIRE ALARM SYSTEM NOTES:

CONTROL SYSTEM. GENERAL REQUIRE— MENTS ARE AS FOLLOWS:

- 1. A FULLY ADDRESSABLE CLASS A U.L. LISTED AND APPROVED FIRE ALARM CONTROL SYSTEM IN ACCORDANCE WITH PROJECT SPECIFICATIONS SHALL BE UTILIZED FOR ENTIRE BLDG. FIRE DETECTION AND ALARM SYSTEM SHALL UTILIZE ANALOG TYPE "SMART" SMOKE SENSORS AND OTHER ADDRESSABLE DEVICES AS INDICATED ON PLANS AND SPECIFICATIONS.
- 2. THE FIRE ALARM AND CONTROL SYSTEM SHALL CONFORM TO PROJECT AND JURISDICTIONAL REQUIREMENTS OF MARCH ARB FIRE MARSHALL. LAYOUT AND REQUIREMENTS FOR FIRE ALARM SYSTEM ARE AS INDICATED ON PLANS AND IN SPECIFICATIONS. CONTRACTOR SHALL BE RESPONSIBLE FOR FINAL DESIGN OF FIRE
- A) FIRE ALARM CONTROL PANEL (FACP) SHALL MONITOR AND CONTROL ALL SMOKE ANDHEAT DETECTORS, MANUAL ALARM PULL STATIONS, DUCT SMOKE DETECTORS, EVACUATION ALARM DEVICES (HORNS, STROBES, ETC), ADDRESSABLE RELAY MODULES AS WELL AS REQUIRED RELAY OUTPUTS.
- B) THE FIRE ALARM SYSTEM SHALL ALSO PROVIDE FOR FOLLOWING INTERFACE FUNCTIONS:
- 1. FACP SHALL PROVIDE OUTPUT CONTROL TO ALL FIRE ANNUNCIATORS AS INDICATED ON PLANS.
- 2. SYSTEM AND DEVICES SHALL BE IN COMPLIANCE WITH ADA REQUIREMENTS.
- 3. MONITOR FIRE WATER SUPPLY VALVE TAMPER SWITCHES INCLUDING REMOTE PIV VALVES.
- 3. THE FIRE ALARM SYSTEM WIRING AND CONDUIT SYSTEM SHALL BE IN STRICT ACCORDANCE WITH BUILDING CODE, NEC, NFPA 72, MANUFACTURERS, CSFM AND LOCAL CODE REQUIREMENTS. ADDRESSABLE SIGNAL "LOOPS" SHALL CONFORM TO "STYLE 6" REQUIREMENTS OF NFPA 72. THE INDICATING APPLIANCE CIRCUITS (HORNS/STROBES, REMOTE RELAY OUTPUTS, ETC) SHALL CONFORM TO "STYLE Z" REQUIREMENTS.
- 4. CONDUCTORS FOR THE FIRE DETECTORS AND ALARM SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH NEC. THE CONDUCTORS SHALL BE INSTALLED IN CONDUIT. FIRE ALARM CONDUCTORS SHALL NOT BE INSTALLED IN JUNCTION BOXES, OUTLET BOXES, OR CONDUITS WITH CONDUCTORS OF LIGHTING AND POWER SYSTEMS. THE SUM OF THE CROSS—AREAS OF INDIVIDUAL CONDUCTORS SHALL NOT EXCEED 40 % OF THE INTERIOR CROSS—SECTIONAL AREA OF THE CONDUIT. FIRE DETECTION AND ALARM CONDUIT SHALL NOT BE LESS THAN 3/4". FOR ADDRESSABLE LOOP CIRCUITS, UTILIZE TWISTED SHIELDED PAIR, APPROVED WIRE #14AWG AS A MINIMUM. ALL WIRING MUST BE COLOR CODED AND LABELED.
- 5. THE FIRE ALARM EQUIPMENT LAYOUT PLANS SHOW APPROXIMATE DEVICE LOCATION. REFER TO ARCHITECTURAL DRAWINGS FOR ROOM DIMENSIONS AND CONSTRUCTION INFORMATION. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO COORDINATE LOCATION OF ALL DEVICES WITH OTHER TRADES AND TO INSURE THAT ALL APPLICABLE NFPA REQUIREMENTS ARE MET (NEC, NFPA 13, , ETC). REQUIRED COORDINATION SHALL INCLUDE LOCATION OF ALL FIRE PROTECTION EQUIPMENT WITH THE BUILDING STRUCTURAL, MECHANICAL, AND ELECTRICAL ELEMENTS INCLUDING, BUT NOT LIMITED TO, STRUCTURAL MEMBERS AND SYSTEM AIR DUCTS AND OUTLETS, LIGHT FIXTURES AND SIMILAR EQUIPMENT AND MATERIAL THAT MAY INTERFERE WITH THE PROPER INSTALLATION AND OPERATION OF THE SYSTEM. CONTRACTOR'S INSTALLATION DRAWINGS SUBMITTED FOR APPROVAL SHALL BE COORDINATED WITH ALL TRADES.
- 6. AREA SMOKE DETECTORS ARE NOT TO BE LOCATED IN DIRECT PATH OF BUILDING'S SUPPLY AIR REGISTERS. LOCATE AT LEAST 3 FEET AWAY FROM REGISTERS. ALL AREA FIRE DETECTORS AT T—BAR CEILING AREAS ARE TO BE LOCATED AT CENTER OF TILE.
- 7. EACH FIRE ALARM SYSTEM ADDRESS POINT SHALL HAVE A CUSTOM IDENTIFYING MESSAGE PROGRAMMED AT FACP. SOFTWARE MESSAGE SHALL APPEAR AT PANELS 32 CHARACTER LCD DISPLAY IF AN ALARM OR TROUBLE CONDITION OCCURS AT ADDRESS. CONTRACTOR SHALL BE RESPONSIBLE TO GENERATE PROPOSED CUSTOM DEVICE MESSAGE IN TABULATED FORM AND OBTAIN FIELD ENGINEER'S APPROVAL PRIOR TO PROGRAMMING OF MESSAGES. THE FIRE ALARM CONTRACTOR IS ALSO RESPONSIBLE FOR COMPLETE PROGRAMMING AND FUNCTIONAL TESTING OF ENTIRE SYSTEM.
- 8. ALL SPRINKLER SYSTEM SWITCHES (TAMPER, WATERFLOW, SUPERVISORY AIR, ETC) ARE TO BE FURNISHED AND INSTALLED BY SPRINKLER CONTRACTOR (SECTION 15330). ALL ELECTRICAL WIRING TERMINATIONS AND CHECKOUT AT DEVICE AND FACP SHALL BE BY FIRE ALARM CONTRACTOR.
- 9. DUCT TYPE SMOKE DETECTORS WITH PROPERLY SIZED SAMPLING TUBES SHALL BE FURNISHED AND INSTALLED WHERE INDICATED IN ACCORDANCE WITH NFPA 72, CBC AND MANUFACTURER'S REQUIREMENTS. UPON ACTIVATION OF A DUCT DETECTOR, THE ASSOCIATED HVAC UNIT SHALL SHUTDOWN AUTOMATICALLY THROUGH OPERATION OF RELAY CONTACTS AT DETECTOR AND AN ALARM CONDITION SHALL OCCUR AT FACP. IF AIR HANDLING UNIT HAS A "SMOKE PURGE" MODE, ACTIVATION OF THE PURGE MODE SHALL OVERRIDE THE UNIT SHUT—DOWN. THE SMOKE DETECTION AND CONTROL FUNCTIONS FOR HVAC UNITS SHALL HAVE THE HIGHEST PRIORITY OVER ALL OTHER HVAC CONTROL MODES. WHERE DUCT DETECTORS ARE INSTALLED ABOVE A DROP CEILING, A REMOTE ALARM INDICATING LAMP SHALL BE FLUSH MOUNTED IN CEILING DIRECTLY BELOW DETECTOR. COORDINATE INSTALLATION AND LOCATION OF EACH DUCT DETECTOR WITH MECHANICAL CONTRACTOR. DETECTOR MUST BE INSTALLED IN A SERVICE ACCESSIBLE LOCATION. PROVIDE ALL ELECTRICAL CONNECTIONS INCLUDING SHUTDOWN WIRING TO AIR HANDLER STARTERS AND SMOKE DAMPERS. COORDINATE SHUTDOWN WIRING WITH HVAC CONTROLS AND ELECTRICAL CONTRACTORS.
- 10. ALL FIRE ALARM CONTROL PANELS, ANNUNCIATOR PANELS AND DEVICES SHALL BE NEATLY FLUSH MOUNTED WITH CONCEALED ELECTRICAL CONDUIT IN AREAS WITH FINISHED WALLS AND CEILINGS. FIRE DETECTOR AND ALARM SYSTEM CONDUIT RUNS SHALL BE STRAIGHT, NEATLY ARRANGED, PROPERLY SUPPORTED AND PERPENDICULAR TO WALLS, CEILINGS AND PARTITIONS. ALL CONDUIT AND WIRING SHALL BE ROUTED IN SUCH A MANNER THAT IT WILL BE CONCEALED FROM VIEW SUCH AS ABOVE CEILING, IN WALLS AND BELOW ACCESS FLOORS. IN UNFINISHED AREAS SUCH AS MECHANICAL ROOMS AND SIMILAR SPACES CONDUIT NEED NOT BE CONCEALED.
- 11. LOCATION AND INSTALLATION METHODS FOR "ADDRESSABLE POINT MONITOR MODULES" MUST BE INDICATED ON SHOP DRAWING SUBMITTALS. MODULES ARE TO BE INSTALLED IN APPROVED NEMA JUNCTION BOX OR ENCLOSURE IN ACCESSIBLE LOCATIONS. WEATHERPROOF ENCLOSURES WITH SEALTIGHT FLEXIBLE CONDUIT ARE REQUIRED AT AREAS SUBJECT TO HIGH MOISTURE (I.E. RISER AND EQUIPMENT ROOMS).
- 12. PRIOR TO BEGINNING INSTALLATION CONTRACTOR IS RESPONSIBLE TO OBTAIN APPROVAL OF SHOP DRAWINGS FROM CONTRACTING OFFICER. A SET OF APPROVED DRAWINGS IS TO BE KEPT AT JOB SITE FOR INSPECTIONS AT ALL TIMES. IN ADDITION, CONTRACTOR IS RESPONSIBLE TO MAINTAIN A CURRENT "AS-BUILT" WORKING SET OF DRAWINGS AT JOB SITE. AS-BUILT DRAWINGS SHALL INDICATE EXACT CONDUIT ROUTING AND SIZING, JUNCTION BOX LOCATION, CONDUCTOR COLORS, COUNTS AND SIZES. AS-BUILT DRAWINGS SHALL ALSO CLEARLY INDICATE LOCATION OF ALL DEVICES AND DETAILS OF INTERFACE WITH AUXILIARY EQUIPMENT. (HVAC SHUTDOWN, SUPPRESSION SYSTEM INTERFACE CENTRAL MONITORING, ETC.).
- 13. ALL FIRE ALARM EQUIPMENT SUPPLIED SHALL BE LISTED BY STATE FIRE MARSHAL.(CSFM)
- 14. REFER TO PROJECT SPECIFICATIONS AND FIRE ALARM AND OPERATION MATRIX FOR FURTHER REQUIREMENTS.

FIRE ALARM SYSTEM OPERATION MATRIX								
	MANUAL PULL STATION	AREA COVERAGE FIRE SENSOR	HVAC UNIT DUCT SMOKE SENSOR	SPRINKLER WATER FLOW SWITCH	SPRINKLER VALVE TAMPER SWITCH	POWER FAILURE	DUCT SMOKE DETECTOR	
ANNUNCIATE AT FIRE CONTROL PANEL (ALARM OR TROUBLE)	•	•		•		•	•	
ANNUNCIATE AT 24 HOUR (1) ATTENDED REMOTE LOCATION AND BLDG ENTRANCE ANNUNCIATOR PNLS	•	•	•	•	•	•	•	
ACTIVATE AUDIBLE/ VISUAL ALARM SIGNAL THROUGHOUT BLDG.	•	•	•	•				
SHUT-DOWN LOCAL AIR HANDLING UNIT		•	•				•	
ACTIVATE (CLOSE) LOCAL FIRE/SMOKE DAMPER								

FIDE ALADMA CYCTEM ADEDATION MATDIY

#### FOOTNOTES

- (1) BUILDING FIRE ALARM PANEL SHALL BE CONNECTED TO THE BASE "MONACO" RADIO TRANSMITTER SYSTEM. SYSTEM FIRE ALARM AND TROUBLE SIGNALS SHALL BE TRANSMITTED TO BASE FIRE CONTROL (24 HOUR/7 DAY FACILITY).
- (2) THE BUILDING WILL BE COMPLETELY SPRINKLED AND MONITORED BY THE FIRE ALARM CONTROL PANEL.

### FIRE ALARM SYSTEM LEGEND

- P DESIGNATION AT DEVICE INDICATES DEVICE ASSOCIATED WITH PREACTION PROTECTED AREA TYP.
- E DESIGNATION AT DEVICE INDICATES DEVICE ASSOCIATED WITH ELEVATOR RECALL TYP.
- A INDICATES ABOVE CEILING
- C INDICATES BELOW CEILING MOUNTING
- WP INDICATES WATERPROOF
- FACP FIRE ALARM AND PREACTION CONTROL PANEL WITH POWER SUPPLY AND BATTERY PACK + 72" TO TOP
- FATC FIRE ALARM TERMINAL CABINET
- ANN ANNUNCIATOR PANEL +72" TO TOP

MAGNETIC DOOR HOLDER

- FSD FIRE/SMOKE DAMPER (SEE MECHANICAL)
- FIRE ALARM MANUAL STATION (ADDRESSABLE) +48" AFF TO CENTER
- FIRE ALARM AUDIO/VISUAL (HORN/STROBE) SIGNAL, ADA COMPLIANT (80")
- MINI-HORN/STROBE ASSEMBLY, ADA (80")
- (1)
  S FIRE ALARM STROBE LIGHT, ADA (80")
- F FIRE ALARM HORN (90" AFF)
- F ALARM BELL (WATERFLOW)
- MASS NOTIFICATION STROBE LIGHT, ADA (80")
- $|\overline{A}|$  mass notification speaker, ada (80°)
- P) PHOTOELECTRIC TYPE SMOKE SENSOR ANALOG ADDRESSABLE
- P)E SMOKE DETECTOR FOR ELEVATOR RECALL
- (T) THERMAL SENSOR ADDRESSABLE TYPE
- D DUCT SMOKE DETECTOR ASSEMBLY PHOTOELECTRIC TYPE (ADDRESSABLE) w/AUX. CONTACTS
- ADDRESSABLE POINT MONITOR MODULE (APMM)
- CONTROL RELAY MODULE (ADDRESSABLE) USE AS REQUIRED
- MM MONITOR MODULE (ADDRESSABLE) USE AS REQUIRED
- $H_{\mathbf{Y}}$  HEAT DETECTOR. F = FIXED TEMPERATURE.
- R = RATE OF RISE.

  Which is a second of the control of the control
- F FIRE ALARM SYSTEM CIRCUIT
- FD SD FIRE/SMOKE DAMPER (PROVIDED BY MECH)
- \* TS VALVE TAMPER (SUPERVISORY) SWITCH
- K FS WATER FLOW ALARM SWITCH
- \* SA SUPERVISORY AIR PRESSURE SWITCH
- SOLENOID VALVE ACTIVATOR
- (1) NO PORTION OF VISUAL DEVICE LENS SHALL BE LESS THAN 80" AFF NOR EXCEED 96" AFF. DEVICES TO BE INSTALLED AT UNIFORM HEIGHT THROUGHOUT. DESIGNATION AT VISUAL DEVICE (15/30/75/110) INDICATES CANDELLA RATING OF DEVICE.
- \* DEVICE PROVIDED UNDER SECTION 211313 (SPRINKLER CONTRACTOR)

FIRE PROTECTION DRAWINGS ARE FOR PERFORMANCE/SCOPE ONLY. CONTRACTOR IS REQUIRED TO SUBMIT SYSTEM SHOP DRAWINGS TO CONTRACTING OFFICER FOR REVIEW AND APPROVAL.

DMJM H&N AECON

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET
CHARLOTTESVILLE, VIRGINIA 22902
T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

CIVIL ENGINEER:

DMJM HARRIS 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2501 F 714.567.2777

LANDSCAPE ARCHITECT:
FIRM NAME
ADDRESS
ADDRESS
PHONE

MECHANICAL, ELECTRICAL & PLUMBING ENGINEER:
DMJM H&N AECOM

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

STRUCTURAL ENGINEER:
DMJM H&N AECOM
999 TOWN AND COUNTRY ROAD
ORANGE, CALIFORNIA 92868

T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT:
SITEWORKS STUDIO


826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902 LIGHTING CONSULTANT:


LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820


CONSTRUCTION MANAGER:
FIRM NAME
ADDRESS
ADDRESS
PHONE


ARCHITECT/ENGINEER STANF


PRELIMINARY - NOT FOR CONSTRUCTION 10/20/2008 30% PRICING 11/07/2008 30% DESIGN REVISION 12/12/2008 60% INTERNAL QA/QC & COST ESTIMATE 12/19/2008 | 60% PRE-FINAL, NASA REVIEW 01/19/2009 | 60% FINAL ISSUE TO NASA 02/16/2009 90% QAQC & COST ESTIMATE DESCRIPTION L DICKENS Ames Research Center N ZECH Moffet Field, California D BAK N232 COLLABORATIVE SUPPORT FACILITY FIRE ALARM LEGEND AND **ABBREVIATIONS** FA001 25307 A232-0800-











DMJM H&N AECOM

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET
CHARLOTTESVILLE, VIRGINIA 22902
T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

CIVIL ENG

PHONE

CIVIL ENGINEER:
DMJM HARRIS
999 TOWN AND COUNTRY ROAD
ORANGE, CALIFORNIA 92868
T 714.567.2501 F 714.567.2777

LANDSCAPE ARCHITECT: FIRM NAME ADDRESS ADDRESS

MECHANICAL, ELECTRICAL & PLUMBING ENGINEER: DMJM H&N AECOM

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

STRUCTURAL ENGINEER:

DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT: SITEWORKS STUDIO 826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902


LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820

CONSTRUCTION MANAGER:
FIRM NAME
ADDRESS
ADDRESS
PHONE

RCHITECT/ENGINEER STAMP

PRELIMINARY - NOT FOR CONSTRUCTION 10/20/2008 30% PRICING 11/07/2008 30% DESIGN REVISION 12/12/2008 60% INTERNAL QA/QC & COST ESTIMATE 12/19/2008 | 60% PRE-FINAL, NASA REVIEW 01/19/2009 | 60% FINAL ISSUE TO NASA 02/16/2009 | 90% QAQC & COST ESTIMATE s kanda Ames Research Center
Moffet Field, California N ZECH D BAK N232 COLLABORATIVE SUPPORT FACILITY
FIRE ALARM MASS NOTIFICATION RISER DIAGRAM 25307 FA401 A232-0800-

SHEET



ALL FIRE PROTECTION EQUIPMENT SUPPLIED SHALL BE APPROVED BY THE ENGINEER. CSFM AND AUTHORITIES HAVING JURISDICTION.

5. ALL SPRINKLER SYSTEMS SHALL BE BRACED AND SUPPORTED IN ACCORDANCE WITH NFPA 13 REQUIREMENTS WITH DUE ALLOWANCES FOR SYSTEM THRUST AND WATER HAMMER FORCES. LOCATIONS AND DETAILS OF ALL PIPING SUPPORTS AND BRACES ARE TO BE INDICATED ON CONTRACTORS SHOP DRAWINGS.

6. ALL FIRE SPRINKLER SYSTEM DESIGN AND SHOP DRAWINGS MUST BE SUBMITTED TO AND APPROVED BY NASA FIRE MARSHALL.

LOCATION OF AUXILLARY DRAINS SHALL BE ACCURATELY DETERMINED PER NFPA 13 AND INSTALLED IN THE FIELD. THE SPRINKLER SYSTEM DRAINAGE SHALL DISCHARGE TO OUTSIDE THE BUILDING TO A DRAIN CAPABLE OF ACCEPTING FULL FLOW UNDER SYSTEM PRESSURE OR TO A LOCATION WHERE WATER DRAINAGE WILL NOT RESULT IN PROPERTY DAMAGE.

8. ALL PIPE PENETRATIONS AT FIRE RATED WALLS SHALL BE SEALED WITH FIRE RATED MATERIAL IN ACCORDANCE WITH APPROVED UL LISTED FIRE SEAL SYSTEM ASSEMBLY.

9. ALL OF THE SPRINKLER PIPING NETWORK EXCEPT SPRINKLER HEAD DROPS SHALL BE SLOPED FOR COMPLETE DRAINAGE. ALL THE ISOLATED LOW POINTS SHALL BE EQUIPPED WITH AUXILLARY DRAINS. DRAINS SHALL CONSIST OF A VALVE NOT SMALLER THAN 3/4" AND A BRASS PLUG.

10. THE CONTRACTOR SHALL COORDINATE THE LOCATIONS OF ALL FIRE PROTECTION EQUIPMENT WITH THE BUILDING'S STRUCTURAL. MECHANICAL AND ELECTRICAL ELEMENTS INCLUDING, BUT NOT LIMITED TO STRUCTURAL MEMBERS, AIR DUCTS AND OUTLETS, LIGHT FIXTURES AND SIMILAR EQUIPMENT AND MATERIALS THAT MAY INTERFERE WITH THE PROPER INSTALLATION AND OPERATION OF THE SYSTEM. THE CONTRACTOR'S COORDINATION SHALL BE REFLECTED ON HIS INSTALLATION DWGS THAT ARE SUBMITTED FOR APPROVAL.

THE FIRE SPRINKLER SYSTEM SHALL BE HYDRAULICALLY CALCULATED PER NFPA 13. SEE SPRINKLER SYSTEM DESIGN SCHEDULE TABLE FOR REQUIREMENTS.

12. THE SPRINKLER PIPING IS TO BE SIZED TO CONFORM WITH THE CONTRACTORS HYDRAULIC CALCULATIONS BASED UPON AVAILABLE WATER SUPPLY SYSTEM.

13. HYDRAULIC CALCULATIONS MUST BE SUBMITTED TO PROVE THE PROPER DESIGN DENSITIES FOR ALL SEPARATELY CLASSIFIED AREAS.

14. THE INSPECTION, HYDROSTATIC TEST AND FLUSHING OF THE SPRINKLER SYSTEM SHALL BE WITNESSED BY THE FIRE DEPTARTMENT.

15. SPACING AND DETAIL OF THE SUPPORT AND BRACING OF FIRE SPRINKLER PIPING SHALL COMPLY WITH LATEST EDITION OF NFPA 13. PROVIDE ANCHORAGE DETAIL AND CALCULATIONS FOR THE CONNECTION OF SWAY BRACING TO THE STRUCTURE. DESIGN LOADS FOR THE ANCHORAGE MAY BE COMPUTED PER TABLE 4-5.4.3,5.1 (a) & (b) OF THE NFPA 13.

16. THE SYSTEM SHALL EMPLOY THE USE OF U.L. APPROVED MATERIALS AND DEVICES.

17. AUTOMATIC SPRINKLER SYSTEM SHALL BE SUPERVISED BY AN APPROVED CENTRAL PROPRIETARY OR REMOTE STATION SERVICE OF A LOCAL ALARM WHICH WILL GIVE AN AUDIBLE SIGNAL AT A CONSTANTLY ATTENDED LOCATION.

18. COORDINATE ALL FIRE PROTECTION TAMPER SWITCHES AND FLOW SWITCHES WITH ELECTRICAL SECTION.

19. ALL VALVES SHALL HAVE A PERMANENTLY AFFIXED SIGN INDICATING ITS FUNCTION.

20. THE ENTIRE PIPING SYSTEM SHALL BE HYDROSTATICALLY TESTED AT 200 PSI FOR TWO HOURS OR AT 50 PSI ABOVE THE SYSTEM OPERATING PRESSURE, WHICHEVER IS GREATER.

21. THE BUILDING N232 FIRE PROTECTION SYSTEM MUST BE FULLY MONITORED BY THE FIRE ALARM SYSTEM INCLUDING BUT NOT LIMITED TO: PIV'S, SECTIONAL CONTROL VALVES, WATER FLOW, ETC.

22. SPRINKLERS WILL BE REQUIRED IN AREAS ABOVE AND BELOW THE CEILING.

SPRINKLER SYSTEM DESIGN SCHEDULE												
BUILDING AREA	SYMBOL	HAZARD CLASS	SYSTEM TYPE	DENSITY (GPM PER SQ. FT.)	SPRINK. SYS. HYDRAULIC DESIGN AREA (SQ. FT.)	MAX. SPACING (SQ. FT.)	SPRI TEMP. *F	POSITION	TYPE	HOSE ALLOWANCE OUTSIDE (GPM)	REMARKS	DURATION MINUTES
OFFICE AREAS		ORDINARY HAZARD GRP. 1	WET PIPE	0.15	1500	130	165	PENDENT (RECESSED) UPRIGHT	BRASS (IN UNFINISHED CEILING AREAS)	500	REFER TO SPECIFICATION SECTION 15300, PART 3, ITEM 3.1A	90

### FIRE SPRINKLER LEGEND & ABBREVIATIONS

— FP— FIRE PROTECTION PIPING

GALLONS

POUNDS

MAXIMUM

**MINIMUM** 

SYSTEM

W/

ASSOCIATION

SQUARE FOOT

SPRINKLER


NOT TO SCALE

GALLONS PER MINUTE


NATIONAL FIRE PROTECTION

OUTSIDE SCREW AND YOKE VALVE

UNDERWRITERS LABORATORIES



WET PIPE SPRINKLER VALVE DETAIL \FP-001 SCALE: NONE




RISER MANIFOLD IS SHOWN CONCEPTUALLY ONLY, IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO PROVIDE ALL PIPING FITTINGS AND VALVE TRIM NECESSARY FOR A COMPLETE, APPROVED AND OPERATIONAL SYSTEM. REFER TO VALVE DETAIL DWGS. FOR MORE DETAIL ON TRIM PIPING FOR EACH VALVE ASSEMBLY. CONNECTIONS TO FIRE ALARM SYSTEM (FACP) NOT SHOWN.

## SPRINKLER RISER ELEVATION DETAIL

SCALE: NONE (CONCEPTUAL)

FIRE PROTECTION DRAWINGS ARE FOR PERFORMANCE/SCOPE ONLY. CONTRACTOR IS REQUIRED TO SUBMIT SPRINKLER SHOP DRAWINGS FOR REVIEW AND APPROVAL. FIRE PROTECTION CONTRACTOR SHALL DO HIS OWN FLOW AND PRESSURE TESTS IN COORDINATION WITH NASA FIRE MARSHALL.

THE FIRE MAIN RUNS EAST AND WEST ALONG THE SOUTH SIDE OF THE BUILDING. THE EXACT PIPING LAYOUT ON SITE SHALL BE VERIFIED IN THE FIELD. BY SURVEYING AND FROM THE NASA MANAGER. IF DRAWINGS ARE NOT AVAILABLE THE EXACT LENGTH, SIZE, MATERIAL, DEPTH AND ALL REQUIRED PERTINENT INFORMATION SHALL BE OBTAINED BY THE CONTRACTOR BY SURVEYING THE SITE. THE CONTRACTOR SHALL ALSO PROVIDE ALL LABOR AND MATERIAL FOR OFF-HOUR POINT OF CONNECTIONS.



ARCHITECT OF RECORD

**CIVIL ENGINEER:** 

DMJM HARRIS

**ADDRESS** 

ADDRESS

PHONE

DMJM H&N

405 HOWARD STREET SUITE 400

SAN FRANCISCO, CALIFORNIA 94105

**WILLIAM MCDONOUGH + PARTNERS** Architecture + Community Design

700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902

1999 TOWN AND COUNTRY ROAD

ORANGE, CALIFORNIA 92868

T 714.567.2501 F 714.567.277

T 714.567.2752 F 714.567.2729

999 TOWN AND COUNTRY ROAD

T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT:

LIGHTING CONSULTANT:

1917 CLEMENT AVENUE, BLDG 10A

ALAMEDA, CALIFORNIA 94501

LOISOS & UBBELOHDE

FIRM NAME

**ADDRESS** 

**ADDRESS** 

STRUCTURAL ENGINEER:

LANDSCAPE ARCHITECT

T 415.365.3200 F 415.267.4957 www.dmimhn.com

T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

A) CONNECTIONS TO FIRE ALARM RISER DIAGRAM SHOW DEVICE CONNECTIONS TO FACP. FOR DEVICE QUANTITIES AND LAYOUT SEE FLOOR PLANS. FINAL SYSTEM DESIGN AND SHOP DRAWING SUBMITTAL TO AOR/EOR IS BY FIRE ALARM CONTRACTOR.

DMJM H&N AECOM

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902 T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

CIVIL ENGINEER:

PHONE

DMJM HARRIS
999 TOWN AND COUNTRY ROAD
ORANGE, CALIFORNIA 92868
T 714.567.2501 F 714.567.2777

LANDSCAPE ARCHITECT: FIRM NAME ADDRESS ADDRESS

MECHANICAL, ELECTRICAL & PLUMBING ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

STRUCTURAL ENGINEER: DMJM H&N AECOM


DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT: SITEWORKS STUDIO 826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902

LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820

CONSTRUCTION MANAGER:
FIRM NAME
ADDRESS
ADDRESS
PHONE

RCHITECT/ENGINEER STAMP



# FIRE SPRINKLER RISER DIAGRAM


SCALE: NONE


| Decked | Date | Date


FIRE PROTECTION DRAWINGS ARE FOR PERFORMANCE/SCOPE ONLY. CONTRACTOR IS REQUIRED TO SUBMIT SYSTEM SHOP DRAWINGS TO AOR/EOR FOR REVIEW AND APPROVAL.

ROOF

1. SPRINKLER HEAD POSITIONS ARE NOTIONAL, AND SHOWN TO INDICATE COORDINATION WITH OTHER HIGH-LEVEL SERVICES. FINAL SPRINKLER HEAD CONTAINS TO BE DETERMINED BY SPECIALIST SPRINKLER CONTRACTOR.







Ames Research Center Moffet Field, California N232 COLLABORATIVE SUPPORT FACILITY
FIRE PROTECTION

V. DANG


A. REED

S. PAINTER

PARTIAL FIRST FLOOR PLAN SOUTH WING 25307

FP212 2 A232-0800-3/32" = 1'-0" INDEX





ARCHITECT OF RECORD DMJM H&N | AECOM

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902 T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

CIVIL ENGINEER:

PHONE

DMJM HARRIS 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2501 F 714.567.2777

LANDSCAPE ARCHITECT: FIRM NAME ADDRESS ADDRESS

MECHANICAL, ELECTRICAL & PLUMBING ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

STRUCTURAL ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT: SITEWORKS STUDIO 826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902

LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820

CONSTRUCTION MANAGER: FIRM NAME ADDRESS ADDRESS PHONE

PRELIMINARY - NOT FOR CONSTRUCTION 10/20/2008 30% PRICING 11/07/2008 30% DESIGN REVISION 12/12/2008 60% INTERNAL QA/QC & COST ESTIMATE 12/19/2008 | 60% PRE-FINAL, NASA REVIEW 01/19/2009 | 60% FINAL ISSUE TO NASA 02/16/2009 90% QAQC & COST ESTIMATE Ames Research Center Moffet Field, California N232 COLLABORATIVE SUPPORT FACILITY
FIRE PROTECTION PARTIAL FIRST FLOOR PLAN


SOUTH BUILDING EAST


25307 A232-0800- FP-214

FP-214


PARTIAL FIRST FLOOR PLAN SOUTH BUILDING EAST FP-214 REF. SCALE: 1/8" = 1'-0"

1. SPRINKLER HEAD POSITIONS ARE NOTIONAL, AND SHOWN TO INDICATE COORDINATION WITH OTHER HIGH-LEVEL SERVICES. FINAL SPRINKLER HEAD CONTAINS TO BE DETERMINED BY SPECIALIST SPRINKLER CONTRACTOR.





DWG: Q:\60048683 - NASA Ames CSF N232\500 CAD\F\Sheet\FP221.dwg User: zechn DATE: Feb 17, 2009 - 9:50:54 am Images: X\_\_62\_\*.AFD03\* "YBDB CUOBT" ".MDD03






ARCHITECT OF RECORD

Amos CCE N929/ 500 CAN) E' Choot' EB992 dus 11000 1

DWG: Q:\60048683 — NASA Ames CSF N232\500 CAD\F\She DATE: Feb 17, 2009 — 9:50:42 am Images:



DMJMH&N AECOM

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902 T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

CIVIL ENGINEER:

PHONE

DMJM HARRIS
999 TOWN AND COUNTRY ROAD
ORANGE, CALIFORNIA 92868
T 714.567.2501 F 714.567.2777

LANDSCAPE ARCHITECT:
FIRM NAME
ADDRESS
ADDRESS

MECHANICAL, ELECTRICAL & PLUMBING ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

STRUCTURAL ENGINEER: DMJM H&N AECOM

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT: SITEWORKS STUDIO 826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902


LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820

CONSTRUCTION MANAGER:
FIRM NAME
ADDRESS
ADDRESS
PHONE

AKCHITECT/ENGINEER STAM

FIRE PROTECTION PARTIAL ROOF PLAN - NORTH BUILDING

EF. SCALE: 3/32'' = 1'-0''



DATE

DATE

L.DICKENS

V. DANG

DATE

DATE

N232 COLLABORATIVE SUPPORT FACILITY
FIRE PROTECTION

PARTIAL ROOF PLAN

PARTIAL ROOF PLAN

PARTIAL ROOF PLAN

NATE

NATE

NATE

NATE

DATE

SIZE

S. PAINTER

DATE

DATE

DATE

DATE

DATE

A REED

A REED

A REED

DATE

N232 COLLABORATIVE SUPPORT FACILITY

FIRE PROTECTION

PARTIAL ROOF PLAN

NORTH BUILDING


SIZE


D 25307 A232-0800- FP231

12/12/2008 60% INTERNAL QA/QC & COST ESTIMATE

12/19/2008 | 60% PRE-FINAL, NASA REVIEW

01/19/2009 | 60% FINAL ISSUE TO NASA





ARCHITECT OF RECORD DMJM H&N | AECOM

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902 T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2501 F 714.567.2777

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729


LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820

PRELIMINARY - NOT FOR CONSTRUCTION

Ames Research Center Moffet Field, California

N232 COLLABORATIVE SUPPORT FACILITY
FIRE PROTECTION PARTIAL ROOF PLAN

> FP-233 A232-0800-



ARCHITECT OF RECORD

DMJM H&N | AECOM

405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com

WILLIAM MCDONOUGH + PARTNERS
Architecture + Community Design

700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902 T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com

CIVIL ENGINEER: DMJM HARRIS 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2501 F 714.567.2777

LANDSCAPE ARCHITECT: FIRM NAME ADDRESS ADDRESS

MECHANICAL, ELECTRICAL & PLUMBING ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

STRUCTURAL ENGINEER: DMJM H&N AECOM

999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729

LANDSCAPE CONSULTANT: SITEWORKS STUDIO 826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902

LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820

CONSTRUCTION MANAGER: FIRM NAME ADDRESS

PRELIMINARY - NOT FOR CONSTRUCTION 11/07/2008 30% DESIGN REVISION 12/12/2008 60% INTERNAL QA/QC & COST ESTIMATE 12/19/2008 | 60% PRE-FINAL, NASA REVIEW 01/19/2009 | 60% FINAL ISSUE TO NASA 02/16/2009 90% QAQC & COST ESTIMATE Ames Research Center Moffet Field, California N232 COLLABORATIVE SUPPORT FACILITY
FIRE PROTECTION PARTIAL ROOF PLAN

FP-234

A232-0800-

				ARCHITECT OF RECORD  AND HAN AECOM  405 HOWARD STREET, SUITE 400 SAN FRANCISCO, CALIFORNIA 94105 T 415.365.3200 F 415.267.4957 www.dmjmhn.com  DESIGN ARCHITECTS  WILLIAM MCDONOUGH + PARTNERS Architecture + Community Design  700 EAST JEFFERSON STREET CHARLOTTESVILLE, VIRGINIA 22902 T 434.979.1111 F 434.979.1112 www.mcdonoughpartners.com  CONSULTANTS  CIVIL ENGINEER: DMJM HARRIS 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2501 F 714.567.2777  LANDSCAPE ARCHITECT: FIRM NAME ADDRESS ADDRESS PHONE  MECHANICAL, ELECTRICAL & PLUMBING ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD
				ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729  STRUCTURAL ENGINEER: DMJM H&N AECOM 999 TOWN AND COUNTRY ROAD ORANGE, CALIFORNIA 92868 T 714.567.2752 F 714.567.2729  LANDSCAPE CONSULTANT: SITEWORKS STUDIO 826-C HINTON AVENUE CHARLOTTESVILLE, VIRGINIA 22902  LIGHTING CONSULTANT: LOISOS & UBBELOHDE 1917 CLEMENT AVENUE, BLDG 10A ALAMEDA, CALIFORNIA 94501 T 510.521.3800 F 510.521.3820  CONSTRUCTION MANAGER: FIRM NAME ADDRESS ADDRESS PHONE
				ARCHITECT/ENGINEER STAMP
DWG: Q:\60048683 — NASA Ames CSF N232\500 CAD\F\Sheet\FP401.dwg User: zechn DATE: Feb 17, 2009 — 9:52:24 am Images: Xrefs: "XBDR		NET PLAN	PROLECT STATUS  PRELIMINARY - NOT  ISSUE  1	ASA REVIEW TO NASA T ESTIMATE  AMBIE RESEARCH Center Moffet Field, California  C COLLABORATIVE SUPPORT FACILITY FIRE PROTECTION DETAILS